



Connecticut Department of

ENERGY &
ENVIRONMENTAL
PROTECTION

BUREAU OF AIR MANAGEMENT
NEW SOURCE REVIEW PERMIT
TO CONSTRUCT AND OPERATE A STATIONARY SOURCE

Issued pursuant to Title 22a of the Connecticut General Statutes (CGS) and Section 22a-174-3a of the Regulations of Connecticut State Agencies (RCSA).

Owner/Operator:	Bridgeport Energy, LLC
Address:	10 Atlantic Street, Bridgeport CT 06604
Equipment Location:	10 Atlantic Street, Bridgeport CT 06604
Equipment Description:	Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town-Permit Numbers:	015-0191
Premises Numbers:	0862
Modification Issue Date:	March 15, 2013
Prior Permit Issue Dates:	05/07/1998 (Permit to Construct) 05/28/1999 (Permit to Operate) 07/11/2012 (Minor Modification) 02/01/2013 (Revision)
Expiration Date:	None

/s/ Anne Gobin for
Daniel C. Esty
Commissioner

March 15, 2013
Date

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

This permit specifies necessary terms and conditions for the operation of this equipment to comply with state and federal air quality standards. The Permittee shall at all times comply with the terms and conditions stated herein.

PART I. DESIGN SPECIFICATIONS

A. General Description

Bridgeport Energy, LLC is a combined cycle electric generating plant providing power to the bulk power system. This facility consists of two Siemens V84.3A combustion turbines with unfired Vogt-NEM heat recovery steam generators, two combustion turbine generators, and a steam turbine generator with a combined nominal rated capacity of 520 MW.

B. Equipment Design Specifications

1. Maximum Fuel Firing Rate: 1,884,000 ft³/hr (natural gas)
2. Maximum Gross Heat Input (MMBTU/hr): 1,884 (natural gas)

C. Control Equipment Design Specifications

1. Low NO_x Burner
 - a. Make and Model: Siemens HR3B
2. Selective Catalytic Reduction (SCR)
 - a. Make and Model: Siemens SINOX
 - b. Catalyst Type: SW 40 D stainless steel honeycomb
3. Oxidation Catalyst
 - a. Make and Model: BASF Camet
 - b. Catalyst Type: 75% corrugated stainless steel foil substrate coated with alumina

D. Stack Parameters

1. Minimum Stack Height (ft): 130
2. Minimum Exhaust Gas Flow Rate (acfm): 961,440 @ 100% load
3. Minimum Stack Exit Temperature (°F): 193 @ 100% load
4. Minimum Distance from Stack to Nearest Property Line (ft): 100

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART II. OPERATIONAL CONDITIONS

A. Equipment Operational Conditions

1. Fuel Type: Natural Gas
2. Maximum Fuel Consumption over any Consecutive 12 Month Period:
33,109,900,000 standard ft³ (scf) combined total for Permit Nos.
015-0190 and 015-0191

PART III. CONTINUOUS EMISSION MONITORING REQUIREMENTS

The Permittee shall comply with the CEM requirements as set forth in RCSA Section 22a-174-4, RCSA Section 22a-174-22, 40 CFR 60 Subpart GG and 40 CFR Parts 72-78, if applicable. CEM shall be required for the following pollutant/operational parameters and enforced on the following basis:

Pollutant/Operational Parameter	Averaging Periods	Units
O ₂	1 hour block	%vd
Steady State, excluding startup/shutdown		
NO _x	24 hour rolling	ppm
CO	1 hour block	ppm

The Permittee shall operate two CO analyzers: a low range (0-20 ppm) and a high range (0-3500 ppm).

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS

A. Monitoring

1. The Permittee shall use a fuel metering device to continuously monitor fuel feed to both Siemens turbines (Permit Nos. 015-0190 and 015-0191).
2. The Permittee shall continuously monitor and continuously record the SCR aqueous ammonia injection rate (gal/hr), operating temperature (°F) and pressure drop (inches of water) across the catalyst bed. The Permittee shall maintain these parameters within the ranges recommended by the manufacturer to achieve compliance with the emission limits in this permit.
3. The Permittee shall continuously monitor and continuously record the oxidation catalyst inlet temperature (°F). The Permittee shall maintain this parameter within the ranges recommended by the manufacturer to achieve compliance with the emission limits in this permit.

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

B. Record Keeping

1. The Permittee shall keep records of the monthly and consecutive 12 month natural gas usage. The consecutive 12 month fuel usage shall be determined by adding the current month's fuel usage to that of the previous 11 months. The Permittee shall make these calculations within 30 days of the end of the previous month.
2. The Permittee shall calculate and record the monthly and consecutive 12 month PM₁₀, PM_{2.5}, SO₂, NO_x, CO, VOC and ammonia emissions in units of tons. The consecutive 12 month emissions shall be determined by adding (for each pollutant) the current month's emissions to that of the previous 11 months. Such records shall include a sample calculation for each pollutant. The Permittee shall make these calculations within 30 days of the end of the previous month.

Emissions during startup, shutdown and equipment tuning shall be counted towards the annual emission limitation in Part V.C of this permit.

3. The Permittee shall record all deviations of any emission limitation or operating parameter. Such records shall include:
 - a. the date and time of the deviation,
 - b. a detailed description of the deviation, and
 - c. the duration of the deviation.

Note: Deviation as defined in 40 CFR 71.6(a)(3)(iii)(C)

4. The Permittee shall keep records of the occurrence and duration of any startup, shutdown, equipment tuning or malfunction in the operation of the stationary gas turbine; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Such records shall contain the following information:

- a. type of event (startup, shutdown, equipment tuning or malfunction),
- b. equipment affected,
- c. date of event,
- d. duration of event (minutes), and
- e. total NO_x and CO emissions emitted (lb) during the event.

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

**DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION
BUREAU OF AIR MANAGEMENT**

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

5. The Permittee shall keep records of each delivery of aqueous ammonia. The records shall include the date of delivery, the name of the supplier, the quantity of aqueous ammonia delivered, and the percentage of ammonia in solution, by weight.
6. The Permittee shall keep records of the inspection and maintenance of the SCR and oxidation catalysts. The records shall include the name of the person, the date, the results or actions and the date the catalyst is replaced.
7. The Permittee shall keep all records required by this permit for a period of no less than five years and shall submit such records to the commissioner upon request.

C. Reporting

1. The Permittee shall notify the commissioner, in writing, of any exceedance from an emissions limitation or operating parameter, and shall identify the cause or likely cause of such exceedance, all corrective actions and preventive measures taken with respect thereto, and the dates of such actions and measures as follows:
 - a. For any hazardous air pollutant, no later than 24 hours after such exceedance commenced; and
 - b. For any other regulated air pollutant or operating parameter, no later than ten days after such exceedance commenced.
2. The Permittee shall notify the commissioner, in writing, of any malfunction of the equipment described in this permit. The Permittee shall submit such notification within ten days of the malfunction. The notification shall include the following:
 - a. a description of the malfunction and a description of the circumstances surrounding the cause or likely cause of such malfunction and,
 - b. a description of all corrective actions and preventive measures taken and/or planned with respect to such malfunction and the dates of such actions and measures.

FIRM NAME: Bridgeport Energy LLC
EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604
EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15 Premises No: 862 Permit No: 191 Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART V. ALLOWABLE EMISSION LIMITS

The Permittee shall not cause or allow this equipment to exceed the emission limits stated herein at any time, as determined in accordance with the applicable averaging periods defined in Part III of this permit or as specified in an approved stack test protocol.

An exceedance of either:

- (1) the emission limits in the tables below, or
- (2) the emissions limits developed for this permit due startup and shutdown shall not be deemed a "Federally Permitted Release," as that term is used in 42 U.S.C. 9601(10).

A. Steady State (Operations following startup until shutdown)

1. Criteria Pollutant Emission Limits

Criteria Pollutants	ppmvd @ 15% O ₂	ppmvw @ 15% O ₂	lb/hr	lb/ MMBTU
PM ₁₀ /PM _{2.5}			3.00	0.0015
SO _x			1.13	0.0006
NO _x	6		41.3	0.0220
VOC		3	7.0	0.0037
CO	10		42.0	0.0223

2. Hazardous Air Pollutant Emission Limits

- a. Ammonia: 6.3 ppmvw @15% O₂
 - b. This unit shall not cause an exceedance of the Maximum Allowable Stack Concentration (MASC) for any hazardous air pollutant (HAP) emitted and listed in RCSA Section 22a-174-29. [State-Only Requirement]
3. **Opacity:** This unit shall not exceed 10% during any six minute block average as measured by 40 CFR 60, Appendix A, Reference Method 9.

B. Startup, Shutdown and Equipment Tuning

1. NO_x startup, shutdown and equipment tuning limit: 500 lb/event.
2. CO startup, shutdown and equipment tuning limit: 4,000 lb/event.
3. The Permittee shall minimize emissions during periods of startup and shutdown by starting the ammonia injection as soon as minimum catalyst temperature is reached.
4. The oxidation catalyst will not be bypassed during startup or shutdown.

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART V. ALLOWABLE EMISSION LIMITS, continued

5. Startup shall be defined as that period of time from initiation of combustion firing until the end of the 180 minutes.
6. Shutdown shall be defined as that period of time from the initial lowering of turbine output until the point at which the combustion process has stopped.
7. Neither startup, nor shutdown, nor equipment tuning events shall ever exceed 180 minutes.
8. Emissions during these periods shall be counted towards the annual emission limits stated herein.

C. Total Allowable Emissions

Total allowable emissions are the combined total emissions, including emissions from startup and shutdown, for Permits Nos. 015-0190 and 015-0191.

Criteria Pollutants	TPY
PM ₁₀ /PM _{2.5}	26.3
SO _x	9.9
NO _x	362.9
VOC	61.5
CO	339.4

- D. Demonstration of compliance with the above emission limits shall be met by calculating the emission rates using emission factors from the following sources:

1. PM₁₀, PM_{2.5}, VOC, Ammonia: Stack test data
2. NO_x, CO: CEM data
3. SO_x: 0.0006 lb/MMBTU [40 CFR Part 75 Appendix D, Section 2.3.1.1].

The commissioner may require other means (e.g. stack testing) to demonstrate compliance with the above emission limits, as allowed by state or federal statute, law or regulation.

FIRM NAME: Bridgeport Energy LLC
 EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604
 EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15 Premises No: 862 Permit No: 191 Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VI. STACK EMISSION TEST REQUIREMENTS

- A. Stack testing shall be performed in accordance with the latest Emission Test Guidelines available on the DEEP website:

http://www.ct.gov/dep/cwp/view.asp?a=2684&q=322076&depNav_GID=1619

Stack emission testing shall be required for the following pollutants:

- PM₁₀/PM_{2.5} SO₂ NO_x CO VOC
 Hazardous Air Pollutants: Ammonia

- B. Within one year of the date of issuance of the minor permit modification to Permit No. 015-0191 (Application No. 201001104), the Permittee shall conduct the initial stack emission testing for VOC, PM₁₀, PM_{2.5} and ammonia. Recurrent stack testing for VOC, PM₁₀, PM_{2.5} and ammonia shall be conducted within five years from the date of the previous stack test. The Permittee shall submit test results within 60 days after completion of testing.
- C. Stack test results shall be reported as follows: VOC, PM₁₀ and PM_{2.5} in units of lb/hr and lb/MMBTU, ammonia in units of µg/m³ and ppmvw at 15% O₂.

PART VII. SPECIAL REQUIREMENTS

- A. The Permittee shall operate and maintain this equipment in accordance with the manufacturer's specifications and written recommendations. The Permittee shall operate and maintain this stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.
- B. The Permittee shall perform inspections of the SCR and oxidation catalysts as recommended by the manufacturer.
- C. The Permittee shall operate this facility at all times in a manner so as not to violate or contribute significantly to the violation of any applicable state noise control regulations, as set forth in RCSA Sections 22a-69-1 through 22a-69-7.4. [State Only Requirement]

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VII. SPECIAL REQUIREMENTS, continued

- D. The Permittee shall comply with all applicable sections of the following New Source Performance Standard(s) at all times.

Title 40 CFR Part 60, Subpart: GG and A

Copies of the Code of Federal Regulations (CFR) are available online at the U.S. Government Printing Office website.

- E. Internal Offset Requirements: *The following language is for historical purposes only*

As of the date of permit issuance, May 7, 1998, for two Siemens turbines (Permit Nos. 015-0190 and 015-0191), the internal offset requirements of former Section 22a-174-3(1) of the RCSA were met by deactivating Bridgeport Harbor Station Unit 1 (Registration No.015-0160).

Pollutant	Bridgeport Harbor Station Unit 1 (Registration No. 015-0160)	External Offsets Required by Permit Nos. 015-0190 and 015-0191	Internal Offsets Required by Permit Nos. 015-0190 and 015-0191
VOC	13.67	67.0	62.1
NOx	795.3	0	532.7
CO	63.3	0	0
PM ₁₀	116.4	0	18.24
SOx	2015.7	0	81.1

- F. The Permittee shall comply with all applicable requirements of the Federal Acid Rain Program codified in Title 40 CFR Parts 72-78, inclusive, by the deadlines set forth within the aforementioned regulation.

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VIII. ADDITIONAL TERMS AND CONDITIONS

- A. This permit does not relieve the Permittee of the responsibility to conduct, maintain and operate the regulated activity in compliance with all applicable requirements of any federal, municipal or other state agency. Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state and local law.
- B. Any representative of DEEP may enter the Permittee's site in accordance with constitutional limitations at all reasonable times without prior notice, for the purposes of inspecting, monitoring and enforcing the terms and conditions of this permit and applicable state law.
- C. This permit may be revoked, suspended, modified or transferred in accordance with applicable law.
- D. This permit is subject to and in no way derogates from any present or future property rights or other rights or powers of the State of Connecticut and conveys no property rights in real estate or material, nor any exclusive privileges, and is further subject to any and all public and private rights and to any federal, state or local laws or regulations pertinent to the facility or regulated activity affected thereby. This permit shall neither create nor affect any rights of persons or municipalities who are not parties to this permit.
- E. Any document, including any notice, which is required to be submitted to the commissioner under this permit shall be signed by a duly authorized representative of the Permittee and by the person who is responsible for actually preparing such document, each of whom shall certify in writing as follows: "I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that any false statement made in the submitted information may be punishable as a criminal offense under section 22a-175 of the Connecticut General Statutes, under section 53a-157b of the Connecticut General Statutes, and in accordance with any applicable statute."
- F. Nothing in this permit shall affect the commissioner's authority to institute any proceeding or take any other action to prevent or abate violations of law, prevent or abate pollution, recover costs and natural resource damages, and to impose penalties for violations of law, including but not limited to violations of this or any other permit issued to the Permittee by the commissioner.

FIRM NAME: Bridgeport Energy LLC

EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604

EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15

Premises No: 862

Permit No: 191

Stack No: 6

PERMIT FOR FUEL BURNING EQUIPMENT

**DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION
BUREAU OF AIR MANAGEMENT**

PART VIII. ADDITIONAL TERMS AND CONDITIONS, continued

- G.** Within 15 days of the date the Permittee becomes aware of a change in any information submitted to the commissioner under this permit, or that any such information was inaccurate or misleading or that any relevant information was omitted, the Permittee shall submit the correct or omitted information to the commissioner.
- H.** The date of submission to the commissioner of any document required by this permit shall be the date such document is received by the commissioner. The date of any notice by the commissioner under this permit, including but not limited to notice of approval or disapproval of any document or other action, shall be the date such notice is personally delivered or the date three days after it is mailed by the commissioner, whichever is earlier. Except as otherwise specified in this permit, the word "day" means calendar day. Any document or action which is required by this permit to be submitted or performed by a date which falls on a Saturday, Sunday or legal holiday shall be submitted or performed by the next business day thereafter.
- I.** Any document required to be submitted to the commissioner under this permit shall, unless otherwise specified in writing by the commissioner, be directed to: Office of Director; Engineering & Enforcement Division; Bureau of Air Management; Department of Energy & Environmental Protection; 79 Elm Street, 5th Floor; Hartford, Connecticut 06106-5127.

FIRM NAME: Bridgeport Energy LLC
 EQUIPMENT LOCATION: 10 Atlantic Street, Bridgeport CT 06604
 EQUIPMENT DESCRIPTION: Siemens V84.3A Turbine (170 MW) with unfired Vogt-NEM Heat Recovery Steam Generator

Town No: 15 Premises No: 862 Permit No: 191 Stack No: 6